

Building Type		County	
Fire - RFPD		Douglas	
Street			
15214 Hwy 138W			
City	State	Zip	
Umpqua	OR	97486	
Latitude		Longitude	
43.51615		123.51963	
Tracking Code		Inspection Date	
RVS in 2006		8/10/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	-0.5	0	0	-0.4	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Kellogg Volunteer FD

Final RVS Score

Final Type

Final Score

S3

2.3

FEMA-154 Collapse Potential

Low (<1%)

No Planview Available



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Torsion: Eccentric Stiffness	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SW Plan Irregularity Primary
back wall is solid indicating a possible Torsion problem.