

Winchester Bay RFPD

Doug_fir40A

Winchester Bay RFPD

Building Type		County	
Fire - RFPD		Douglas	
Street			
30 6th St			
City	State	Zip	
Winchester Bay	OR	97467	
Latitude		Longitude	
43.67775		124.17491	
Tracking Code		Inspection Date	
RVS in 2006		8/24/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Secondary	W1	4.4	0	-0.5	0	0	0	0	0	3.9
Tertiary		0	0	0	0	0	0	0	0	0

Winchester Bay RFPD

Final RVS Score

Final Type

Final Score

RM1

1.7

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Torsion: Eccentric Stiffness	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SE Primary Structural Type
secondary structural type also