

Building Type Police - City	County Douglas	
Street 637 NE Locust St		
City Oakland	State OR	Zip 97462
Latitude 43.42399	Longitude 123.2941	
Tracking Code RVS in 2006	Inspection Date 8/11/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	0	-0.5	-0.2	0	0	0	0	1.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Oakland Police Dept

## Final RVS Score

Final Type	Final Score
URM	1.1

## FEMA-154 Collapse Potential

Moderate (&gt;1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1900
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	Yes	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Unreinforced Chimneys		None	
None		None	
None		None	
			
NW Falling Hazard		NW Primary Structural Type	

