

Douglas County Sheriff's Office

Douglas County

Doug_pol11A

Building Type Police - County	County Douglas	
Street 647 E 1st St.		
City Riddle	State OR	Zip 97469
Latitude 42.952	Longitude 123.35702	
Tracking Code RVS in 2006	Inspection Date 8/30/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	0	0	0	0	4.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Douglas County Sheriff's Office

Final RVS Score

Final Type	Final Score
W1	4.4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Douglas County Sheriff's Office

Doug_pol11A

Enrollment 210	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built 1970
Total Area (square ft)	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 SW Primary Structural Type			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries