

Fir Grove Elementary School

Douglas County SD 4

Doug_sch02A

Building Type	County	
School	Douglas	
Street		
1360 W Harvard Ave		
City	State	Zip
Roseburg	OR	97470
Latitude	Longitude	
43.21555	123.36508	
Tracking Code	Inspection Date	
RVS in 2006	8/26/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	0	0	0	-0.4	0	0	1.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Fir Grove Elementary School

Final RVS Score

Final Type	Final Score
W2	1.4

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Fir Grove Elementary School

Doug_sch02A

Enrollment 284	Year Built (Field Verified) 1961	Year Built (Alt. Source) 1960	Est. Decade Built 1960
Total Area (square ft) 48000	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
			
SW General Site	NE General Site	NW General Site	