

Hucrest Elementary School

Douglas County SD 4

Doug_sch05A

Building Type School	County Douglas	
Street 1810 NW Kline St		
City Roseburg	State OR	Zip 97470
Latitude 43.23114	Longitude 123.38103	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary	RM1	2.8	-1	-0.5	0	0	0	0	0	1.3
Tertiary		0	0	0	0	0	0	0	0	0

Hucrest Elementary School

Final RVS Score

Final Type	Final Score
W2	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Hucrest Elementary School

Doug_sch05A

Enrollment 428	Year Built (Field Verified) 1955	Year Built (Alt. Source) 1955	Est. Decade Built 1970
Total Area (square ft) 44971	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W Plan Irregularity Primary	NW Elevation View	NW Plan Irregularity Secondary	
			
NE Vertical Irregularity Primary and reentrant corner.	NE Vertical Irregularity Primary and reentrant corner	E Primary Structural Type and secondary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries