

Sunnyslope Elementary School

Douglas County SD 4

Doug_sch07A

Building Type School	County Douglas	
Street 2230 SW Cannon Rd		
City Roseburg	State OR	Zip 97470
Latitude 43.15413	Longitude 123.38827	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Tertiary		0	0	0	0	0	0	0	0	0

Sunnyslope Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Sunnyslope Elementary School

Doug_sch07A

Enrollment 240	Year Built (Field Verified) 1965	Year Built (Alt. Source) 1960	Est. Decade Built 1960
Total Area (square ft) 41891	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
			
SW Plan Irregularity Primary	S Elevation View	SE Plan Irregularity Primary	
			
SE Plan Irregularity Primary	SE Primary Structural Type secondary structure type, reentrant corner, elevation step.	NE Primary Structural Type and secondary structural type. The wall on the left is W2 and the wall on the right is RM.	
			
N Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries