

Coffenberry Middle School

South Umpqua SD 19

Doug_sch15A

Building Type	County
School	Douglas
Street	
591 NE Rice St	
City	State Zip
Myrtle Creek	OR 97457
Latitude	Longitude
43.02944	123.28159
Tracking Code	Inspection Date
RVS in 2006	8/25/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	-0.4	0	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Coffenberry Middle School

Final RVS Score

Final Type	Final Score
W2	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Coffenberry Middle School

Doug_sch15A

Enrollment 368	Year Built (Field Verified) 1930	Year Built (Alt. Source) 1930	Est. Decade Built 1940
Total Area (square ft) 22829	Number of Stories 2	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities Building On Hill or Sloped Site None None	
Falling Hazards None None None		Poor Conditions None None None	
 S 2 Number of Stories		 S Elevation View entrance way	
 N Elevation View		 NW Plan Irregularity Primary	
 SE Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Coffenberry Middle School

South Umpqua SD 19

Doug_sch15B

Building Type	County
School	Douglas
Street	
591 NW Rice St	
City	State Zip
Myrtle Creek	OR 97457
Latitude	Longitude
43.02931	123.28273
Tracking Code	Inspection Date
RVS in 2006	8/25/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	0	0	0	-0.4	0	0	1.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Coffenberry Middle School

Final RVS Score

Final Type	Final Score
RM1	1.4

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Coffenberry Middle School

Doug_sch15B

Enrollment 368	Year Built (Field Verified) 1930	Year Built (Alt. Source) 1930	Est. Decade Built 1960
Total Area (square ft) 22829	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Short Columns None None	
Falling Hazards None None None		Poor Conditions Cracks None None	
			
SW Primary Structural Type	W Poor Condition	N Elevation View	
			
N Elevation View	SE Elevation View		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries