

West Sutherlin Intermediate

Sutherlin SD 130

Doug_sch29A

Building Type	County	
School	Douglas	
Street		
531 N Comstock Rd		
City	State	Zip
Sutherlin	OR	97479
Latitude	Longitude	
43.39181	123.3317	
Tracking Code	Inspection Date	
RVS in 2006	8/11/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

West Sutherlin Intermediate

Final RVS Score

Final Type	Final Score
W2	1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

West Sutherlin Intermediate

Doug_sch29A

Enrollment 377	Year Built (Field Verified) 1953	Year Built (Alt. Source) 1953	Est. Decade Built 1950
Total Area (square ft) 34065	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Very Irregular Changes Building On Hill or Sloped Site None	
Falling Hazards None None None		Poor Conditions None None None	
			
E Vertical Irregularity Primary		NE Vertical Irregularity Primary also shows a reentrant corner and a sloped site	
		SW Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

West Sutherlin Intermediate

Sutherlin SD 130

Doug_sch29B

Building Type	County
School	Douglas
Street	
531 N Comstock Rd	
City	State Zip
Sutherlin	OR 97479
Latitude	Longitude
43.39179	123.3322
Tracking Code	Inspection Date
RVS in 2006	8/11/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	0	0	0	3.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

West Sutherlin Intermediate

Final RVS Score

Final Type	Final Score
W2	3.8

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

West Sutherlin Intermediate

Doug_sch29B

Enrollment 349	Year Built (Field Verified) 1953	Year Built (Alt. Source) 1953	Est. Decade Built 1950
Total Area (square ft) 34065	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Building On Hill or Sloped Site Steps in Elevation View: Single Change None	
Falling Hazards None None None		Poor Conditions None None None	
			
W	Vertical Irregularity Secondary	S	Elevation View
			
S	Elevation View	S	Elevation View
			
NW Vertical Irregularity Secondary and sloped site.			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries