

Camas Valley School

Camas Valley SD 21J

Doug_sch40A

Building Type School	County Douglas	
Street 197 Main Camas Rd		
City Camas Valley	State OR	Zip 97416
Latitude 43.03456	Longitude 123.67503	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	-0.5	-1	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Camas Valley School

Final RVS Score

Final Type	Final Score
C2	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Camas Valley School

Doug_sch40A

Enrollment 162	Year Built (Field Verified) 1928	Year Built (Alt. Source) 1928	Est. Decade Built 1920
Total Area (square ft) 39030	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 N Plan Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Camas Valley School

Camas Valley SD 21J

Doug_sch40B

Building Type School	County Douglas	
Street 197 Main Camas Rd		
City Camas Valley	State OR	Zip 97416
Latitude 43.03483	Longitude 123.67522	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	0	0	0	0	0	0	4.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Camas Valley School

Final RVS Score

Final Type	Final Score
W1	4.4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Camas Valley School

Doug_sch40B

Enrollment 162	Year Built (Field Verified) 1948	Year Built (Alt. Source) 1928	Est. Decade Built 1940
Total Area (square ft) 39030	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	

Camas Valley School

Camas Valley SD 21J

Doug_sch40C

Building Type School	County Douglas	
Street 197 Main Camas Rd		
City Camas Valley	State OR	Zip 97416
Latitude 43.03468	Longitude 123.67473	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	-0.4	0	0	2.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Camas Valley School

Final RVS Score

Final Type	Final Score
RM1	2.4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Camas Valley School

Doug_sch40C

Enrollment 162	Year Built (Field Verified) 1952	Year Built (Alt. Source) 1928	Est. Decade Built 1950
Total Area (square ft) 39030	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	

Camas Valley School

Camas Valley SD 21J

Doug_sch40D

Building Type School	County Douglas	
Street 197 Main Camas Rd		
City Camas Valley	State OR	Zip 97416
Latitude 43.03417	Longitude 123.67569	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	-0.4	0	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Camas Valley School

Final RVS Score

Final Type	Final Score
PC1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Camas Valley School

Doug_sch40D

Enrollment 162	Year Built (Field Verified) 1970	Year Built (Alt. Source) 1928	Est. Decade Built 1970
Total Area (square ft) 39030	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E Vertical Irregularity Primary		N Plan Irregularity Secondary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Camas Valley School

Camas Valley SD 21J

Doug_sch40E

Building Type School	County Douglas	
Street 197 Main Camas Rd		
City Camas Valley	State OR	Zip 97416
Latitude 43.0339	Longitude 123.67595	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Camas Valley School

Final RVS Score

Final Type	Final Score
W1	1.4

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Camas Valley School

Doug_sch40E

Enrollment 162	Year Built (Field Verified) 1978	Year Built (Alt. Source) 1928	Est. Decade Built 1970
Total Area (square ft) 39030	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
			
W Vertical Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries