

City Of Condon VFD/PD

Gill_fir01A

City of Condon

Building Type	County
Fire - City	Gilliam
Street	
128 S Main St	
City	State Zip
Condon	OR 97823
Latitude	Longitude
45.23646	120.18447
Tracking Code	Inspection Date
RVS in 2006	8/29/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	0	-0.4	0	-0.8	0	0	0.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

City Of Condon VFD/PD

Final RVS Score

Final Type	Final Score
C2	0.4

FEMA-154 Collapse Potential


High (>10%)



OregonGeology

City Of Condon VFD/PD

Gill_fir01A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1938	1938	1930
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
6481	2	No	Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: L Shaped		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
Reentrant Corners: L Shaped (Adjacent Build/Entity)		None	
None		None	
Falling Hazards		Poor Conditions	
Unreinforced Chimneys		None	
None		None	
None		None	
			
NW Elevation View		W Building Name	
		W Pounding Potential	
			
NE Elevation View		NE Falling Hazard	



OregonGeology


Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

City Of Condon VFD/PD

Gill_fir01B

City of Condon

Building Type	County
Fire - City	Gilliam
Street	
128 S Main St	
City	State Zip
Condon	OR 97823
Latitude	Longitude
45.23643	120.18435
Tracking Code	Inspection Date
RVS in 2006	8/29/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

City Of Condon VFD/PD

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

City Of Condon VFD/PD

Gill_fir01B

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1938	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners:L shaped (Adjacent Build/Entity)		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
None		Building On Hill or Sloped Site	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NE Elevation View		SE Elevation View B ONLY CONNECTS TO A	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries