

Arlington High School

Arlington SD 3

Gill_sch03A

Building Type	County	
School	Gilliam	
Street		
1200 Main St		
City	State	Zip
Arlington	OR	97812
Latitude	Longitude	
45.7124	120.19996	
Tracking Code	Inspection Date	
RVS in 2006	8/29/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Arlington High School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Arlington High School

Gill_sch03A

Enrollment 44	Year Built (Field Verified) 1952	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 29359	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: L Shaped		Steps in Elevation View: Single Change	
Reentrant Corners: Other (Adjacent Build/Entity)		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
Out of Plane Lateral-Force-Resistance Elements		Building On Hill or Sloped Site	
Falling Hazards		Poor Conditions	
Other: Brick Veneer		None	
None		None	
None		None	
			
W General Site	NW Elevation View YR 2000 CONST	N Plan Irregularity Tertiary	
			
N Primary Structural Type	NE Elevation View	NE Primary Structural Type WOOD SIDING BENEATH BRICK	
			
SE Vertical Irregularity Tertiary	SE Plan Irregularity Primary	S Primary Structural Type	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Arlington High School

Arlington SD 3

Gill_sch03B

Building Type	County
School	Gilliam
Street	
1200 Main St	
City	State Zip
Arlington	OR 97812
Latitude	Longitude
45.71203	120.19993
Tracking Code	Inspection Date
RVS in 2006	8/29/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Tertiary		0	0	0	0	0	0	0	0	0

Arlington High School

Final RVS Score

Final Type	Final Score
C2	0.3

FEMA-154 Collapse Potential

High (>10%)




OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Arlington High School

Gill_sch03B

Enrollment 44	Year Built (Field Verified) 1952	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 1	Number of Stories 1	Basement No	Pounding Potential Yes
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other	Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: 2 to 3 Changes	Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)
None		Building On Hill or Sloped Site	
Falling Hazards		Poor Conditions	
Other: Brick Veneer	None	None	None
None		None	
None		None	
			
W Elevation View	NW Elevation View		
			
SE Plan Irregularity Primary	S Primary Structural Type FORM MARKS		
			
S Primary Structural Type	SW Primary Structural Type W WALL IS WOOD STUD ACCORDING TO MAINT STAFF		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries