

# Mount Vernon Fire Department

City of Mt Vernon

Gran\_fir02A

Building Type	County
Fire - City	Grant
Street	
199 W Main	
City	State Zip
Mount Vernon	OR 97865
Latitude	Longitude
44.41715	119.11486
Tracking Code	Inspection Date
RVS in 2006	7/28/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	-0.5	0	0	-0.2	0	0	4.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mount Vernon Fire Department

## Final RVS Score

Final Type	Final Score
W1	4.5

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Mount Vernon Fire Department

Gran\_fir02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		Other	
None		None	
None		None	



E Primary Structural Type  
hole shows w1 construction nothing else would allow a hole like that



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries