

Prairie City FD and Police

City of Prairie City

Gran_fir07A

Building Type Fire - City	County Grant	
Street 133 S Bridge St		
City Prairie City	State OR	Zip 97869
Latitude 44.46193	Longitude 118.71082	
Tracking Code RVS in 2006	Inspection Date 7/27/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0


Prairie City FD and Police

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Prairie City FD and Police

Gran_fir07A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1978	1978	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: T shaped		Steps in Elevation View: 2 to 3 Changes	
Torsion: Eccentric Stiffness		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W	Plan Irregularity Primary	W	Field Verified Year Built
			
		W	Plan Irregularity Primary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries