

Long Creek School

Long Creek SD 17

Gran_sch01A

Building Type School	County Grant	
Street 375 E Main St.		
City Long Creek	State OR	Zip 97856
Latitude 44.71343	Longitude 119.09956	
Tracking Code RVS in 2006	Inspection Date 7/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Long Creek School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Long Creek School

Gran_sch01A

Enrollment 50	Year Built (Field Verified) 1971	Year Built (Alt. Source) 1950	Est. Decade Built
Total Area (square ft) 11885	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: T shaped Reentrant Corners: Other None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
			
NW Elevation View		SW Plan Irregularity Secondary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Long Creek School

Long Creek SD 17

Gran_sch01B

Building Type School	County Grant	
Street 375 E Main St.		
City Long Creek	State OR	Zip 97856
Latitude 44.71342	Longitude 119.09899	
Tracking Code RVS in 2006	Inspection Date 7/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Long Creek School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Long Creek School

Gran_sch01B

Enrollment 50	Year Built (Field Verified) 1971	Year Built (Alt. Source) 1971	Est. Decade Built 1960
Total Area (square ft) 11885	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
			
N Vertical Irregularity Primary		E Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Long Creek School

Long Creek SD 17

Gran_sch01C

Building Type School	County Grant	
Street 375 E Main St.		
City Long Creek	State OR	Zip 97856
Latitude 44.71313	Longitude 119.0999	
Tracking Code RVS in 2006	Inspection Date 7/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary	S3	3.8	0	-0.5	0	0	-0.6	0	0	2.7
Tertiary		0	0	0	0	0	0	0	0	0

Long Creek School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Long Creek School

Gran_sch01C

Enrollment 50	Year Built (Field Verified) 1971	Year Built (Alt. Source) 1971	Est. Decade Built 1960
Total Area (square ft) 11885	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
 W General Site		 SW General Site	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries