

# Prairie City School

Prairie City SD 4

Gran\_sch02A

Building Type		County	
School		Grant	
Street			
740 Overholt St			
City	State	Zip	
Prairie City	OR	97869	
Latitude		Longitude	
44.45614		118.70915	
Tracking Code		Inspection Date	
RVS in 2006		7/27/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	3.4	-1.5	-0.5	-0.4	0	0	-0.8	0	0.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Prairie City School

## Final RVS Score

Final Type

Final Score

URM

0.2

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
157		1929	1920
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
13356	1	No	No

Plan Irregularities	Vertical Irregularities
Lateral-Force-Resistance in One Direction Only	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



E Vertical Irregularity Primary



W Vertical Irregularity Primary



W Plan Irregularity Primary



E Elevation View



S Primary Structural Type



# Prairie City School

Prairie City SD 4

Gran\_sch02B

Building Type		County	
School		Grant	
Street			
740 Overholt St			
City	State	Zip	
Prairie City	OR	97869	
Latitude		Longitude	
44.45576		118.70899	
Tracking Code		Inspection Date	
RVS in 2006		7/27/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	-0.2	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Prairie City School

## Final RVS Score

Final Type

Final Score

W2

-0.1

## FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
157		1929	1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
13356	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners:Other (Adjacent Build/Entity)	Steps in Elevation View: 2 to 3 Changes
None	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None

# Prairie City School

Prairie City SD 4

Gran\_sch02C

Building Type		County	
School		Grant	
Street			
740 Overholt St			
City	State	Zip	
Prairie City	OR	97869	
Latitude		Longitude	
44.45627		118.70973	
Tracking Code		Inspection Date	
RVS in 2006		7/27/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	-0.2	0	0	-1.2	0	2.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Prairie City School

## Final RVS Score

Final Type

Final Score

W2

2.9

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
157		1929	1930
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
13356	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners:T shaped (Adjacent Build/Entity)	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



W Elevation View



# Prairie City School

Prairie City SD 4

Gran\_sch02D

Building Type		County	
School		Grant	
Street			
740 Overholt St			
City	State	Zip	
Prairie City	OR	97869	
Latitude		Longitude	
44.4565		118.70917	
Tracking Code		Inspection Date	
RVS in 2006		7/27/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	0	-1.2	0	0.1
Secondary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Prairie City School

## Final RVS Score

Final Type

Final Score

RM1

-0.1

## FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
157		1929	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
13356	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners:L shaped (Adjacent Build/Entity)	Steps in Elevation View: Single Change
None	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



W Plan Irregularity Primary



W Vertical Irregularity Primary



N Elevation View



E Elevation View



E Plan Irregularity Primary





# Prairie City School

Prairie City SD 4

Gran\_sch02E

Building Type		County	
School		Grant	
Street			
740 Overholt St			
City	State	Zip	
Prairie City	OR	97869	
Latitude		Longitude	
44.45579		118.70962	
Tracking Code		Inspection Date	
RVS in 2006		7/27/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Prairie City School

## Final RVS Score

Final Type

Final Score

RM1

-0.1

## FEMA-154 Collapse Potential

Very High (100%)




OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
157		1929	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
13356	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: L Shaped	Steps in Elevation View: Single Change (Adjacent Building/Entity)
Reentrant Corners: Other	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



N Elevation View



# Prairie City School

Prairie City SD 4

Gran\_sch02F

Building Type		County	
School		Grant	
Street			
740 Overholt St			
City	State	Zip	
Prairie City	OR	97869	
Latitude		Longitude	
44.45602		118.71055	
Tracking Code		Inspection Date	
RVS in 2006		7/27/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Prairie City School

## Final RVS Score

Final Type

Final Score

RM1

-0.1

## FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
157		1929	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
13356	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: L Shaped	Steps in Elevation View: Single Change
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



N Elevation View



# Prairie City School

Prairie City SD 4

Gran\_sch02G

Building Type		County	
School		Grant	
Street			
740 Overholt St			
City	State	Zip	
Prairie City	OR	97869	
Latitude		Longitude	
44.45602		118.71102	
Tracking Code		Inspection Date	
RVS in 2006		7/27/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	-0.5	0	0	0	-1	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Prairie City School

## Final RVS Score

Final Type

Final Score

S3

2.3

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
157		1929	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
13356	1	No	No

Plan Irregularities	Vertical Irregularities
Torsion: Eccentric Stiffness	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None

