

Mount Vernon Middle School

John Day SD 3

Gran_sch04A

Building Type	County
School	Grant
Street	
35 School Ln	
City	State Zip
Mount Vernon	OR 97865
Latitude	Longitude
44.41855	119.11594
Tracking Code	Inspection Date
RVS in 2006	7/28/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	-0.2	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mount Vernon Middle School

Final RVS Score

Final Type	Final Score
W2	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Mount Vernon Middle School

Gran_sch04A

Enrollment 163	Year Built (Field Verified) 1916	Year Built (Alt. Source) 1916	Est. Decade Built 1910
Total Area (square ft) 28990	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) Reentrant Corners: Other None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) Steps in Elevation View: 2 to 3 Changes None	
Falling Hazards Unreinforced Chimneys None None		Poor Conditions Other None None	
			
E Vertical Irregularity Primary		E Vertical Irregularity Primary	
			
E Poor Condition		SE Plan Irregularity Secondary	
			
		SE Falling Hazard	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mount Vernon Middle School

John Day SD 3

Gran_sch04B

Building Type	County
School	Grant
Street	
35 School Ln	
City	State Zip
Mount Vernon	OR 97865
Latitude	Longitude
44.41888	119.11582
Tracking Code	Inspection Date
RVS in 2006	7/28/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	-0.4	0	-0.8	0	0	-0.1
Secondary	RM1	3.6	-2	-0.5	-0.4	0	-0.8	0	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Mount Vernon Middle School

Final RVS Score

Final Type	Final Score
C2	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Mount Vernon Middle School

Gran_sch04B

Enrollment 163	Year Built (Field Verified) 1916	Year Built (Alt. Source) 1916	Est. Decade Built 1940
Total Area (square ft) 28990	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) Reentrant Corners: Other None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes Steps in Elevation View: 2 to 3 Changes None	
Falling Hazards None None None		Poor Conditions None None None	
 SE Vertical Irregularity Primary		 NE Elevation View	
		 NW Plan Irregularity Secondary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mount Vernon Middle School

John Day SD 3

Gran_sch04C

Building Type	County	
School	Grant	
Street		
35 School Ln		
City	State	Zip
Mount Vernon	OR	97865
Latitude	Longitude	
44.41874	119.11599	
Tracking Code	Inspection Date	
RVS in 2006	7/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	-0.4	0	-0.8	0	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mount Vernon Middle School

Final RVS Score

Final Type	Final Score
RM1	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Mount Vernon Middle School

Gran_sch04C

Enrollment 163	Year Built (Field Verified) 1916	Year Built (Alt. Source) 1916	Est. Decade Built 1940
Total Area (square ft) 28990	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
 NW Primary Structural Type			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mount Vernon Middle School

John Day SD 3

Gran_sch04D

Building Type	County	
School	Grant	
Street		
35 School Ln		
City	State	Zip
Mount Vernon	OR	97865
Latitude	Longitude	
44.41834	119.11622	
Tracking Code	Inspection Date	
RVS in 2006	7/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mount Vernon Middle School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Mount Vernon Middle School

Gran_sch04D

Enrollment 163	Year Built (Field Verified) 1916	Year Built (Alt. Source) 1916	Est. Decade Built 1960
Total Area (square ft) 28990	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
 N Elevation View		 NW Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mount Vernon Middle School

John Day SD 3

Gran_sch04E

Building Type	County
School	Grant
Street	
35 School Ln	
City	State Zip
Mount Vernon	OR 97865
Latitude	Longitude
44.41836	119.11665
Tracking Code	Inspection Date
RVS in 2006	7/28/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	0	0	0	-0.8	0	0	4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mount Vernon Middle School

Final RVS Score

Final Type	Final Score
W2	4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Mount Vernon Middle School

Gran_sch04E

Enrollment 163	Year Built (Field Verified) 1916	Year Built (Alt. Source) 1916	Est. Decade Built 1970
Total Area (square ft) 28990	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 NW General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries