

Monument School

Monument SD 8

Gran_sch08A

Building Type School	County Grant	
Street 127 North St		
City Monument	State OR	Zip 97864
Latitude 44.82064	Longitude 119.41935	
Tracking Code RVS in 2006	Inspection Date 7/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	3.4	-1.5	-0.5	-0.4	0	-0.4	0	0	0.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Monument School

Final RVS Score

Final Type	Final Score
URM	0.6

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Monument School

Gran_sch08A

Enrollment 56	Year Built (Field Verified) 1929	Year Built (Alt. Source) 1920	Est. Decade Built 1920
Total Area (square ft) 10000	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Internal Discontinuous Diaphram (large internal opening) None None	
Falling Hazards None None None		Poor Conditions None None None	
 S Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Monument School

Monument SD 8

Gran_sch08B

Building Type School	County Grant	
Street 127 North St		
City Monument	State OR	Zip 97864
Latitude 44.82073	Longitude 119.41982	
Tracking Code RVS in 2006	Inspection Date 7/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	-0.4	0	-0.8	0	0	-0.1
Secondary	RM1	3.6	-2	-0.5	-0.4	0	-0.8	0	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Monument School

Final RVS Score

Final Type	Final Score
C2	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Monument School

Gran_sch08B

Enrollment 56	Year Built (Field Verified) 1929	Year Built (Alt. Source) 1940	Est. Decade Built 1940
Total Area (square ft) 10000	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
 SW General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Monument School

Monument SD 8

Gran_sch08C

Building Type School	County Grant	
Street 127 North St		
City Monument	State OR	Zip 97864
Latitude 44.82094	Longitude 119.42028	
Tracking Code RVS in 2006	Inspection Date 7/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	0	0	0	-0.8	0	0	1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Monument School

Final RVS Score

Final Type	Final Score
W2	1

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Monument School

Gran_sch08C

Enrollment 56	Year Built (Field Verified) 1929	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 10000	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
 N Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Monument School

Monument SD 8

Gran_sch08D

Building Type School	County Grant	
Street 127 North St		
City Monument	State OR	Zip 97864
Latitude 44.82108	Longitude 119.41913	
Tracking Code RVS in 2006	Inspection Date 7/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	1.6	-0.8	0	0	5.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Monument School

Final RVS Score

Final Type	Final Score
W2	5.1

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Monument School

Gran_sch08D

Enrollment 56	Year Built (Field Verified) 1929	Year Built (Alt. Source) 1929	Est. Decade Built 1980
Total Area (square ft) 10000	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 S General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries