

Harney District Hospital - Burns

Publically Owned NFP - Burns

Harn_hos01A

Building Type Hospital	County Harney	
Street 557 West Washington Street		
City Burns	State OR	Zip 97720
Latitude 43.58835	Longitude 119.06022	
Tracking Code New Building	Inspection Date 6/28/2006	



Seismicity Zone: Moderate										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	0	-0.5	0	0	-0.8	0	0	2.3
Secondary	W2	4.8	0	-0.5	0	0	-0.8	0	0	3.5
Tertiary		0	0	0	0	0	0	0	0	0

Harney District Hospital - Burns

Final RVS Score

Final Type

Final Score

C2

2.3

FEMA-154 Collapse Potential

Low (<1%)



Harney District Hospital - Burns

Harn_hos01A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		2008	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	Yes	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: E Shaped		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Other: Brick Veneer		None	
None		None	
None		None	
			
S	Elevation View	S	Elevation View
			
		S	General Site new hos being built



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries