

Burns Police Dept

City of Burns

Harn_pol03A

Building Type Police - City	County Harney	
Street 60 W Van Buren St		
City Burns	State OR	Zip 97720
Latitude 43.58386	Longitude 119.05512	
Tracking Code RVS in 2006	Inspection Date 6/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	0	0	1.6	0	-0.6	0	6.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Burns Police Dept

Final RVS Score

Final Type	Final Score
W1	6.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1990	1950	1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	



E General Site

