

Burns High School

Harney County SD 3

Harn_sch02A

Building Type	County	
School	Harney	
Street		
1100 Oregon Street		
City	State	Zip
Burns	OR	97720
Latitude	Longitude	
43.57589	119.07459	
Tracking Code	Inspection Date	
RVS in 2006	6/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Burns High School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Burns High School

Harn_sch02A

Enrollment 315	Year Built (Field Verified) 1959	Year Built (Alt. Source) 1959	Est. Decade Built 1950
Total Area (square ft) 67876	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards Other: Brick Veneer None None		Poor Conditions None None None	
			
E Elevation View		W Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries