

Henry L Slater Elementary School

Harney County SD 3

Harn sch03A

Building Type	County	
School	Harney	
Street		
800 North Fairview		
City	State	Zip
Burns	OR	97720
Latitude	Longitude	
43.59275	119.06088	
Tracking Code	Inspection Date	
RVS in 2006	6/29/2006	

Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

Henry L Slater Elementary School

Final RVS Score

Final Type	Final Score
------------	-------------

C2 0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Henry L Slater Elementary School

Harn_sch03A

Enrollment 428	Year Built (Field Verified) 1948	Year Built (Alt. Source) 1917	Est. Decade Built 1940
Total Area (square ft) 45595	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards Other: Smokestack None None		Poor Conditions None None None	
			
E Elevation View	E Elevation View	S Elevation View	
			
W Falling Hazard			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Henry L Slater Elementary School

Harney County SD 3

Harn_sch03B

Building Type	County	
School	Harney	
Street		
800 North Fairview		
City	State	Zip
Burns	OR	97720
Latitude	Longitude	
43.59207	119.06102	
Tracking Code	Inspection Date	
RVS in 2006	6/29/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	-0.5	0	0	-0.8	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Henry L Slater Elementary School

Final RVS Score

Final Type	Final Score
RM1	2.3

FEMA-154 Collapse Potential

Low (<1%)



Henry L Slater Elementary School

Harn_sch03B

Enrollment 428	Year Built (Field Verified) 1917	Year Built (Alt. Source) 1917	Est. Decade Built 1970
Total Area (square ft) 45595	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Henry L Slater Elementary School

Harney County SD 3

Harn_sch03C

Building Type	County	
School	Harney	
Street		
800 North Fairview		
City	State	Zip
Burns	OR	97720
Latitude	Longitude	
43.59252	119.06203	
Tracking Code	Inspection Date	
RVS in 2006	6/29/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Henry L Slater Elementary School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Henry L Slater Elementary School

Harn_sch03C

Enrollment 428	Year Built (Field Verified) 1917	Year Built (Alt. Source) 1917	Est. Decade Built 1950
Total Area (square ft) 45595	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards Other: Smokestack Other: Brick Veneer None		Poor Conditions None None None	
 E Elevation View		 E General Site	
 E General Site		 SW Falling Hazard	