

# Crane Elementary School

Harney County SD 4

Harn\_sch04A

Building Type	County	
School	Harney	
Street		
43277 Crane-Venator Ln		
City	State	Zip
Crane	OR	97732
Latitude	Longitude	
43.41698	118.57611	
Tracking Code	Inspection Date	
RVS in 2006	6/29/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	0	0	0	0	-1.2	0	0.6
Secondary	S3	3.8	0	0	0	0	0	-1	0	2.8
Tertiary		0	0	0	0	0	0	0	0	0

Crane Elementary School

## Final RVS Score

Final Type	Final Score
W2	0.6

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

# Crane Elementary School

Harn\_sch04A

Enrollment 80	Year Built (Field Verified) 1961	Year Built (Alt. Source) 1961	Est. Decade Built 1960
Total Area (square ft) 18000	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
			
S Elevation View	S Elevation View	E Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries