

Westside RFPD

Hood_fir04A

Westside RFPD

Building Type		County	
Fire - RFPD		Hood	
Street			
1185 Tucker Road			
City	State	Zip	
Hood River	OR	97031	
Latitude		Longitude	
45.6853		121.52731	
Tracking Code		Inspection Date	
RVS in 2006		8/3/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	0	0	0	-0.8	0	0	1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Westside RFPD

Final RVS Score

Final Type

Final Score

W2

1

FEMA-154 Collapse Potential

High (>10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1972	1972	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: L Shaped	Steps in Elevation View: Single Change
Torsion: Eccentric Stiffness	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Elevation View



W Elevation View

