

Westside RFPD

Hood_fir07A

Westside RFPD

Building Type Fire - RFPD	County Hood	
Street 4250 Barrett Drive		
City Hood River	State OR	Zip 97031
Latitude 45.67872	Longitude 121.56417	
Tracking Code RVS in 2006	Inspection Date 8/3/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Westside RFPD

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1946	1946	1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: L Shaped		Steps in Elevation View: 2 to 3 Changes	
Torsion: Eccentric Stiffness		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S	Elevation View	SW	General Site



Westside RFPD Shelter

Hood_fir07B

Westside RFPD

Building Type Fire - RFPD	County Hood	
Street 4260 Barrett Drive		
City Hood River	State OR	Zip 97031
Latitude 45.67883	Longitude 121.56498	
Tracking Code RVS in 2006	Inspection Date 8/3/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	0	-0.2	0	-0.8	0	0	3.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Westside RFPD Shelter

Final RVS Score

Final Type	Final Score
W2	3.8

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Westside RFPD Shelter

Hood_fir07B

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1889	1946	Pre 1900
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	Yes	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries