

Westside Elementary School

Hood River County SD

Hood_sch02A

Building Type School	County Hood	
Street 3685 Belmont Dr		
City Hood River	State OR	Zip 97031
Latitude 45.695	Longitude 121.54326	
Tracking Code RVS in 2006	Inspection Date 8/2/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	0	-0.8	0	0	3.5
Secondary	C2	3.6	0	-0.5	0	0	-0.8	0	0	2.3
Tertiary		0	0	0	0	0	0	0	0	0

Westside Elementary School

Final RVS Score

Final Type	Final Score
C2	2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Westside Elementary School

Hood_sch02A

Enrollment 460	Year Built (Field Verified) 1969	Year Built (Alt. Source) 1969	Est. Decade Built 1960
Total Area (square ft) 64760	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 S General Site		 N Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Westside Elementary School

Hood River County SD

Hood_sch02B

Building Type School	County Hood	
Street 3685 Belmont Dr		
City Hood River	State OR	Zip 97031
Latitude 45.69569	Longitude 121.54315	
Tracking Code RVS in 2006	Inspection Date 8/2/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	0	0	0	-0.8	0	0	1
Secondary	C2	3.6	-2	0	0	0	-0.8	0	0	0.8
Tertiary		0	0	0	0	0	0	0	0	0

Westside Elementary School

Final RVS Score

Final Type	Final Score
C2	0.8

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Westside Elementary School

Hood_sch02B

Enrollment 460	Year Built (Field Verified) 1969	Year Built (Alt. Source) 1969	Est. Decade Built 1960
Total Area (square ft) 64760	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
N Elevation View		E General Site steel posts w wood beams	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Westside Elementary School

Hood River County SD

Hood_sch02C

Building Type School	County Hood	
Street 3685 Belmont Dr		
City Hood River	State OR	Zip 97031
Latitude 45.6954	Longitude 121.54326	
Tracking Code RVS in 2006	Inspection Date 8/2/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S2	3.6	-2	0	0	1.4	-0.8	0	0	2.2
Secondary	W2	4.8	-3	0	0	1.6	-0.8	0	0	2.6
Tertiary		0	0	0	0	0	0	0	0	0

Westside Elementary School

Final RVS Score

Final Type	Final Score
S2	2.2

FEMA-154 Collapse Potential


Low (<1%)



OregonGeology

Westside Elementary School

Hood_sch02C

Enrollment 460	Year Built (Field Verified) 1995	Year Built (Alt. Source) 1969	Est. Decade Built 1990
Total Area (square ft) 64760	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
 S General Site		 E General Site	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Westside Elementary School

Hood River County SD

Hood_sch02D

Building Type	County	
School	Hood	
Street		
3685 Belmont Dr		
City	State	Zip
Hood River	OR	97031
Latitude	Longitude	
45.69499	121.54272	
Tracking Code	Inspection Date	
RVS in 2006	8/2/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S2	3.6	0	-0.5	0	1.4	-0.8	0	0	3.7
Secondary	W2	4.8	0	-0.5	0	1.6	-0.8	0	0	5.1
Tertiary	RM1	3.6	0	-0.5	0	0	-0.8	0	0	2.3

Westside Elementary School

Final RVS Score

Final Type	Final Score
RM1	2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Westside Elementary School

Hood_sch02D

Enrollment 460	Year Built (Field Verified) 1995	Year Built (Alt. Source) 1969	Est. Decade Built 1990
Total Area (square ft) 64760	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
E	Elevation View	E	Elevation View
			
S	Elevation View		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries