

# May Street Elementary School

Hood River County SD

Hood\_sch06A

Building Type	County	
School	Hood	
Street		
911 May Street		
City	State	Zip
Hood River	OR	97031
Latitude	Longitude	
45.70374	121.52048	
Tracking Code	Inspection Date	
RVS in 2006	8/3/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S1	3.6	-2	-0.5	0	0	0	-1	0	0.1
Secondary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

May Street Elementary School

## Final RVS Score

Final Type	Final Score
RM1	-0.1

## FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

# May Street Elementary School

Hood\_sch06A

Enrollment 422	Year Built (Field Verified) 1957	Year Built (Alt. Source) 1957	Est. Decade Built 1950
Total Area (square ft) 44354	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: H Shaped None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) Short Columns None	
Falling Hazards Other: Smokestack Other: Ornamental Hazard Over Exit None		Poor Conditions None	
			
N Primary Structural Type	N General Site	N Other short columns	
			
N Primary Structural Type	W Elevation View	W Primary Structural Type	
			
S Falling Hazard			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# May Street Elementary School

Hood River County SD

Hood\_sch06B

Building Type	County	
School	Hood	
Street		
911 May Street		
City	State	Zip
Hood River	OR	97031
Latitude	Longitude	
45.70342	121.52029	
Tracking Code	Inspection Date	
RVS in 2006	8/3/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

May Street Elementary School

## Final RVS Score

Final Type	Final Score
C2	-0.1

## FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

# May Street Elementary School

Hood\_sch06B

Enrollment 422	Year Built (Field Verified) 1957	Year Built (Alt. Source) 1957	Est. Decade Built 1940
Total Area (square ft) 44354	Number of Stories 2	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
			
S General Site	SE Elevation View	W Primary Structural Type	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# May Street Elementary School

Hood River County SD

Hood\_sch06C

Building Type	County
School	Hood
Street	
911 May Street	
City	State Zip
Hood River	OR 97031
Latitude	Longitude
45.70343	121.51999
Tracking Code	Inspection Date
RVS in 2006	8/3/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S4	3.6	0	-0.5	0	1.2	0	-1.2	0	3.1
Secondary	C2	3.6	0	-0.5	0	1.6	0	-1.2	0	3.5
Tertiary	RM1	3.6	0	-0.5	0	2	0	-1.2	0	3.9

May Street Elementary School

## Final RVS Score

Final Type	Final Score
S4	3.1

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# May Street Elementary School

Hood\_sch06C

Enrollment 422	Year Built (Field Verified) 1957	Year Built (Alt. Source) 1957	Est. Decade Built 2000
Total Area (square ft) 44354	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities None None None	
Falling Hazards Other: Brick Veneer None None		Poor Conditions None None None	
			
W General Site	S Elevation View	E Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries