

Mid Valley Elementary School

Hood River County SD

Hood_sch07A

Building Type School	County Hood	
Street 3686 Davis Road		
City Odell	State OR	Zip 97044
Latitude 45.62488	Longitude 121.54256	
Tracking Code RVS in 2006	Inspection Date 8/4/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	-0.4	0	-0.8	0	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mid Valley Elementary School

Final RVS Score

Final Type	Final Score
C2	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Mid Valley Elementary School

Hood_sch07A

Enrollment 409	Year Built (Field Verified) 1937	Year Built (Alt. Source) 1937	Est. Decade Built 1930
Total Area (square ft) 68162	Number of Stories 2	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards Other: Smokestack None None		Poor Conditions None None None	
			
N Falling Hazard			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mid Valley Elementary School

Hood River County SD

Hood_sch07B

Building Type School	County Hood	
Street 3686 Davis Road		
City Odell	State OR	Zip 97044
Latitude 45.62502	Longitude 121.54309	
Tracking Code RVS in 2006	Inspection Date 8/4/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Tertiary		0	0	0	0	0	0	0	0	0

Mid Valley Elementary School

Final RVS Score

Final Type	Final Score
C2	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Mid Valley Elementary School

Hood_sch07B

Enrollment 409	Year Built (Field Verified) 1954	Year Built (Alt. Source) 1937	Est. Decade Built 1950
Total Area (square ft) 68162	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: T shaped Reentrant Corners: L Shaped (Adjacent Build/Entity) None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) Short Columns None	
Falling Hazards Other: Smokestack None None		Poor Conditions None None None	
 N Elevation View			

Mid Valley Elementary School

Hood River County SD

Hood_sch07C

Building Type	County	
School	Hood	
Street		
3686 Davis Road		
City	State	Zip
Odell	OR	97044
Latitude	Longitude	
45.625	121.54386	
Tracking Code	Inspection Date	
RVS in 2006	8/4/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	0	-0.5	0	1.6	-0.8	0	0	3.9
Secondary	S4	3.6	0	-0.5	0	1.2	-0.8	0	0	3.5
Tertiary		0	0	0	0	0	0	0	0	0

Mid Valley Elementary School

Final RVS Score

Final Type	Final Score
S4	3.5

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Mid Valley Elementary School

Hood_sch07C

Enrollment 409	Year Built (Field Verified) 1937	Year Built (Alt. Source) 1937	Est. Decade Built 2000
Total Area (square ft) 68162	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
E Primary Structural Type		S Elevation View	
		W Elevation View	
			
NE Elevation View gym			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries