

Pine Grove Elementary School

Hood River County SD

Hood_sch09A

Building Type School	County Hood	
Street 2405 Eastside Road		
City Hood River	State OR	Zip 97031
Latitude 45.65277	Longitude 121.49832	
Tracking Code RVS in 2006	Inspection Date 8/4/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	0	-0.5	-0.4	0	-0.8	0	0	1.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Pine Grove Elementary School

Final RVS Score

Final Type	Final Score
C2	1.9

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Pine Grove Elementary School

Hood_sch09A

Enrollment 127	Year Built (Field Verified) 1925	Year Built (Alt. Source) 1925	Est. Decade Built 1920
Total Area (square ft) 22540	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: U shaped		Building On Hill or Sloped Site	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
Other: Smokestack		None	
None		None	
None		None	
			
E	Elevation View	S	Elevation View
			
S	Falling Hazard	S	Falling Hazard
			
W	Elevation View	N	Elevation View



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Pine Grove Elementary School

Hood River County SD

Hood_sch09B

Building Type	County	
School	Hood	
Street		
2405 Eastside Road		
City	State	Zip
Hood River	OR	97031
Latitude	Longitude	
45.65253	121.4983	
Tracking Code	Inspection Date	
RVS in 2006	8/4/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	0	0	0	-0.8	0	0	4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Pine Grove Elementary School

Final RVS Score

Final Type	Final Score
W2	4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Pine Grove Elementary School

Hood_sch09B

Enrollment 127	Year Built (Field Verified) 1925	Year Built (Alt. Source) 1925	Est. Decade Built 1950
Total Area (square ft) 22540	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards Other: Smokestack		Poor Conditions None None None	
 N Elevation View		 W Falling Hazard	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries