

Table Rock - Workforce Training Center

Jack_coc07A

Rogue CC

Building Type	County	
Community_College	Jackson	
Street		
7800 Pacific Avenue		
City	State	Zip
White City	OR	97503
Latitude	Longitude	
42.44047	122.83438	
Tracking Code	Inspection Date	
Miller 2004-05	7/25/2005	

Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	3.4	-1.5	-0.5			-0.4			1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Table Rock - Workforce Training Center

Final RVS Score

Final Type	Final Score
URM	1

FEMA-154 Collapse Potential

High (>10%)

Table Rock Campus

7800 Pacific Avenue
White City, OR 97503
(541) 245-7500

Legend

- Rogue Central
- Electronics Department
- Diesel Department
- Construction Department
- Manufacturing Department
- Phoenix Learning Center
- Fire Science/EMT and Criminal Justice
- Classrooms and Offices
- Common Areas and Offices
- Second Floor
- Room Number



Rogue Community College



Table Rock - Workforce Training Center

Jack_coc07A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
13627	1942	1942	1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
13627	2	No	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		Yes: Unknown	
Falling Hazards		Poor Conditions	
None			
None			
None			