

Jackson County Fire District #3

Jackson Co Fire District #3

Jack_fir02A

Building Type	County	
Fire - RFPD	Jackson	
Street		
8333 Agate Rd		
City	State	Zip
White City	OR	97503
Latitude	Longitude	
42.43766	122.85659	
Tracking Code	Inspection Date	
RVS in 2006	7/17/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary	C1	3	-2	-0.5	0	0	-0.6	0	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Jackson County Fire District #3

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Jackson County Fire District #3

Jack_fir02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1977	1977	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Out of Plane Lateral-Force-Resistance Elements		Steps in Elevation View: 2 to 3 Changes	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W Vertical Irregularity Primary Also shows large doors on both sides of the building indicating that there is not a torsion problem.		E Plan Irregularity Primary	
		W Vertical Irregularity Primary	
E Field Verified Year Built			