

# City Of Phoenix

Jack\_fir03A

City Of Phoenix

Building Type Fire - City	County Jackson	
Street 116 W 2nd St		
City Phoenix	State OR	Zip 97535
Latitude 42.27442	Longitude 122.81696	
Tracking Code RVS in 2006	Inspection Date 6/30/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	-0.5	0	0	-0.8	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

City Of Phoenix

## Final RVS Score

Final Type	Final Score
RM1	2.3

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Other: Light Cladding		None	
None		None	
None		None	
			
S	Plan Irregularity Primary	S	Vertical Irregularity Primary
			
S	Falling Hazard		

