

Lake Creek Rural Fire District

Lake Creek RFPD

Jack_fir17A

Building Type	County	
Fire - RFPD	Jackson	
Street		
1584 S Fork Little Butte		
City	State	Zip
Eagle Point	OR	97524
Latitude	Longitude	
42.42076	122.62292	
Tracking Code	Inspection Date	
RVS in 2006	7/17/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	-3.5	-0.5	0	1.6	-0.2	0	0	2.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lake Creek Rural Fire District

Final RVS Score

Final Type	Final Score
W1	2.6

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Lake Creek Rural Fire District

Jack_fir17A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1982	1982	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Out of Plane Lateral-Force-Resistance Elements		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE Elevation View		W Vertical Irregularity Primary	
			
		W Field Verified Year Built 1982	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries