

|                   |       |                 |  |
|-------------------|-------|-----------------|--|
| Building Type     |       | County          |  |
| Fire - City       |       | Jackson         |  |
| Street            |       |                 |  |
| 276 Mill Creek Dr |       |                 |  |
| City              | State | Zip             |  |
| Prospect          | OR    | 97536           |  |
| Latitude          |       | Longitude       |  |
| 42.75212          |       | 122.48853       |  |
| Tracking Code     |       | Inspection Date |  |
| RVS in 2006       |       | 7/24/2006       |  |



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

|           | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary   | W1   | 5.2         | -3.5       | -0.5       | 0        | 0          | -0.2   | 0      | 0      | 1         |
| Secondary |      | 0           | 0          | 0          | 0        | 0          | 0      | 0      | 0      | 0         |
| Tertiary  |      | 0           | 0          | 0          | 0        | 0          | 0      | 0      | 0      | 0         |

Prospect Fire Department

## Final RVS Score

Final Type

Final Score

W1

1

FEMA-154 Collapse Potential

High (&gt;10%)

# No Planview Available



|                        |                             |                          |                    |
|------------------------|-----------------------------|--------------------------|--------------------|
| Enrollment             | Year Built (Field Verified) | Year Built (Alt. Source) | Est. Decade Built  |
|                        |                             |                          | 1960               |
| Total Area (square ft) | Number of Stories           | Basement                 | Pounding Potential |
|                        | 2                           | No                       | No                 |

|                              |                                         |
|------------------------------|-----------------------------------------|
| Plan Irregularities          | Vertical Irregularities                 |
| Torsion: Eccentric Stiffness | Steps in Elevation View: 2 to 3 Changes |
| None                         | None                                    |
| None                         | None                                    |

|                 |                 |
|-----------------|-----------------|
| Falling Hazards | Poor Conditions |
| None            | None            |
| None            | None            |
| None            | None            |



N Vertical Irregularity Primary

