

Butte Falls Police Dept

City of Butte Falls

Jack_pol06A

Building Type Police - City	County Jackson	
Street 431 Broad St		
City Butte Falls	State OR	Zip 97522
Latitude 42.5438	Longitude 122.56646	
Tracking Code RVS in 2006	Inspection Date 7/18/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	-0.5	0	0	-0.2	0	0	4.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Butte Falls Police Dept

Final RVS Score

Final Type	Final Score
W1	4.5

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	Yes
Plan Irregularities		Vertical Irregularities	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	

S Pounding Potential

