

Building Type	County	
Fire - City	Jackson	
Street		
1155 E Main St		
City	State	Zip
Ashland	OR	97520
Latitude	Longitude	
42.19437	122.69824	
Tracking Code	Inspection Date	
RVS in 2006	6/29/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	0	0	1.6	-0.8	0	0	5.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Ashland Police Department

Final RVS Score

Final Type

Final Score

W2

5.6

FEMA-154 Collapse Potential

Low (<1%)

No Planview Available



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
None	None
None	None
None	None

Falling Hazards	Poor Conditions
Other: General	None
None	None
None	None



S Other
About 10' of the building buried all along the west side.



SE Falling Hazard



E Other
The date of the building in the front of this police station. Looks like both might have been constructed at the same time.



E Other
NE corner buried.