

Building Type		County	
Police - City		Jackson	
Street			
300 Mill Creek Dr			
City	State	Zip	
Prospect	OR	97536	
Latitude		Longitude	
42.75186		122.48849	
Tracking Code		Inspection Date	
RVS in 2006		7/24/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	0	0	0	-0.2	0	0	5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Prospect Police Department

Final RVS Score

Final Type

Final Score

W1

5

FEMA-154 Collapse Potential

Low (<1%)

No Planview Available



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
None	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None