

Building Type	County	
School	Jackson	
Street		
1070 Tolman Creek Rd		
City	State	Zip
Ashland	OR	97520
Latitude	Longitude	
42.17572	122.67056	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Bellview Elementary School

Final RVS Score

Final Type	Final Score
C2	0.3

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



Bellview Elementary School

Jack_sch03A

Enrollment 276	Year Built (Field Verified) 1952	Year Built (Alt. Source) 1952	Est. Decade Built
Total Area (square ft) 37744	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	