

Richardson Elementary School

Central Point SD 6

Jack_sch11A

Building Type		County	
School		Jackson	
Street			
200 W Pine St			
City	State	Zip	
Central Point	OR	97502	
Latitude		Longitude	
42.37301		122.92127	
Tracking Code		Inspection Date	
RVS in 2006		7/18/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	0	-1.2	0	0.1
Secondary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Richardson Elementary School

Final RVS Score

Final Type

Final Score

RM1

-0.1

FEMA-154 Collapse Potential

Very High (100%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
516		1964	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
32476	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: Very Irregular Changes
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Vertical Irregularity Primary

N General Site
Shows RM1 for the lower part and W2 for the upper part. Also shows a vertical irregularity.

E Plan Irregularity Primary



W Plan Irregularity Primary

