

White City Elementary School

Eagle Point SD 9

Jack_sch16A

Building Type	County
School	Jackson
Street	
2830 Maple Court Dr	
City	State Zip
White City	OR 97503
Latitude	Longitude
42.43043	122.84041
Tracking Code	Inspection Date
RVS in 2006	7/17/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	0	0	0	-0.8	0	0	4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

White City Elementary School

Final RVS Score

Final Type	Final Score
W2	4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

White City Elementary School

Jack_sch16A

Enrollment 489	Year Built (Field Verified) 1965	Year Built (Alt. Source) 1965	Est. Decade Built 1960
Total Area (square ft) 44968	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

White City Elementary School

Eagle Point SD 9

Jack_sch16B

Building Type	County	
School	Jackson	
Street		
2830 Maple Court Dr		
City	State	Zip
White City	OR	97503
Latitude	Longitude	
42.43078	122.83995	
Tracking Code	Inspection Date	
RVS in 2006	7/17/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Secondary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Tertiary	S3	3.8	0	-0.5	0	0	-0.6	0	0	2.7

White City Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

White City Elementary School

Jack_sch16B

Enrollment 489	Year Built (Field Verified) 1965	Year Built (Alt. Source) 1965	Est. Decade Built 1960
Total Area (square ft) 44968	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
			
N Vertical Irregularity Primary also shows two lateral systems.		NE Vertical Irregularity Primary also shows out of plan irregularity.	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

White City Elementary School

Eagle Point SD 9

Jack_sch16C

Building Type	County	
School	Jackson	
Street		
2830 Maple Court Dr		
City	State	Zip
White City	OR	97503
Latitude	Longitude	
42.43013	122.84009	
Tracking Code	Inspection Date	
RVS in 2006	7/17/2006	



Seismicity Zone: Moderate										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	0	-0.8	0	0	3.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

White City Elementary School

Final RVS Score

Final Type	Final Score
W2	3.5

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

White City Elementary School

Jack_sch16C

Enrollment 489	Year Built (Field Verified) 1965	Year Built (Alt. Source) 1965	Est. Decade Built 1970
Total Area (square ft) 44968	Number of Stories 1	Basement No	Pounding Potential No
Plan Irregularities Non-Parallel System None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	

White City Elementary School

Eagle Point SD 9

Jack_sch16D

Building Type	County
School	Jackson
Street	
2830 Maple Court Dr	
City	State Zip
White City	OR 97503
Latitude	Longitude
42.4301	122.84084
Tracking Code	Inspection Date
RVS in 2006	7/17/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	0	-0.8	0	0	3.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

White City Elementary School

Final RVS Score

Final Type	Final Score
W2	3.5

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

White City Elementary School

Jack_sch16D

Enrollment 489	Year Built (Field Verified) 1965	Year Built (Alt. Source) 1965	Est. Decade Built 1970
Total Area (square ft) 44968	Number of Stories 1	Basement No	Pounding Potential No
Plan Irregularities Non-Parallel System None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	

White City Elementary School

Eagle Point SD 9

Jack_sch16E

Building Type	County	
School	Jackson	
Street		
2830 Maple Court Dr		
City	State	Zip
White City	OR	97503
Latitude	Longitude	
42.43066	122.84081	
Tracking Code	Inspection Date	
RVS in 2006	7/17/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	0	-0.8	0	0	3.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

White City Elementary School

Final RVS Score

Final Type	Final Score
W2	3.5

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

White City Elementary School

Jack_sch16E

Enrollment 489	Year Built (Field Verified) 1965	Year Built (Alt. Source) 1965	Est. Decade Built 1970
Total Area (square ft) 44968	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Non-Parallel System None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	