

Mountain View Elementary

Eagle Point SD 9

Jack_sch17A

Building Type	County
School	Jackson
Street	
7837 Hale Way	
City	State Zip
White City	OR 97503
Latitude	Longitude
42.42999	122.83845
Tracking Code	Inspection Date
RVS in 2006	7/17/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	0	0	0	-0.8	0	0	2.8
Secondary	W2	4.8	0	0	0	0	-0.8	0	0	4
Tertiary		0	0	0	0	0	0	0	0	0

Mountain View Elementary

Final RVS Score

Final Type	Final Score
RM1	2.8

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Mountain View Elementary

Jack_sch17A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
366	1978	1978	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
43575	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE	General Site	E	Field Verified Year Built



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mountain View Elementary

Eagle Point SD 9

Jack_sch17B

Building Type	County
School	Jackson
Street	
7873 Hale Way	
City	State Zip
White City	OR 97503
Latitude	Longitude
42.43044	122.8384
Tracking Code	Inspection Date
RVS in 2006	7/17/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	0	0	0	-0.8	0	0	1
Secondary	RM1	3.6	-2	0	0	0	-0.8	0	0	0.8
Tertiary		0	0	0	0	0	0	0	0	0

Mountain View Elementary

Final RVS Score

Final Type	Final Score
RM1	0.8

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Mountain View Elementary

Jack_sch17B

Enrollment 366	Year Built (Field Verified) 1978	Year Built (Alt. Source) 1978	Est. Decade Built 1970
Total Area (square ft) 43575	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
 NE Primary Structural Type also show secondary structure type.		 S General Site	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mountain View Elementary

Eagle Point SD 9

Jack_sch17C

Building Type	County
School	Jackson
Street	
7873 Hale Way	
City	State Zip
White City	OR 97503
Latitude	Longitude
42.43012	122.83887
Tracking Code	Inspection Date
RVS in 2006	7/17/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	-0.5	0	0	-0.8	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mountain View Elementary

Final RVS Score

Final Type	Final Score
RM1	2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Mountain View Elementary

Jack_sch17C

Enrollment 366	Year Built (Field Verified) 1978	Year Built (Alt. Source) 1978	Est. Decade Built 1970
Total Area (square ft) 43575	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
SE Plan Irregularity Primary reentrant corner		SE Plan Irregularity Primary reentrant corner	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mountain View Elementary

Eagle Point SD 9

Jack_sch17D

Building Type	County
School	Jackson
Street	
7873 Hale Way	
City	State Zip
White City	OR 97503
Latitude	Longitude
42.42985	122.83892
Tracking Code	Inspection Date
RVS in 2006	7/17/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	-0.5	0	0	-0.8	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mountain View Elementary

Final RVS Score

Final Type	Final Score
RM1	2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Mountain View Elementary

Jack_sch17D

Enrollment 366	Year Built (Field Verified) 1978	Year Built (Alt. Source) 1978	Est. Decade Built 1970
Total Area (square ft) 43575	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 S General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries