

Eagle Point High School

Eagle Point SD 9

Jack_sch19A

Building Type	County
School	Jackson
Street	
203 N Platt Ave	
City	State Zip
Eagle Point	OR 97524
Latitude	Longitude
42.47496	122.80195
Tracking Code	Inspection Date
RVS in 2006	7/17/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Eagle Point High School

Final RVS Score

Final Type	Final Score
C2	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Eagle Point High School

Jack_sch19A

Enrollment 1218	Year Built (Field Verified) 1982	Year Built (Alt. Source) 1982	Est. Decade Built 1970
Total Area (square ft) 177000	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
 <p>S Plan Irregularity Primary also show elevation step.</p>			

Eagle Point High School

Eagle Point SD 9

Jack_sch19B

Building Type	County	
School	Jackson	
Street		
203 N Platt Ave		
City	State	Zip
Eagle Point	OR	97524
Latitude	Longitude	
42.47555	122.80258	
Tracking Code	Inspection Date	
RVS in 2006	7/17/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	0	0	0	-0.8	0	0	0.8
Secondary	RM1	3.6	-2	0	0	0	-0.8	0	0	0.8
Tertiary	S3	3.8	0	0	0	0	-0.6	0	0	3.2

Eagle Point High School

Final RVS Score

Final Type	Final Score
C2	0.8

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Eagle Point High School

Jack_sch19B

Enrollment 1218	Year Built (Field Verified) 1982	Year Built (Alt. Source) 1982	Est. Decade Built 1970
Total Area (square ft) 177000	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
			
N Primary Structural Type and plan irregularity.			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Eagle Point High School

Eagle Point SD 9

Jack_sch19C

Building Type	County	
School	Jackson	
Street		
203 N Platt Ave		
City	State	Zip
Eagle Point	OR	97524
Latitude	Longitude	
42.47569	122.80201	
Tracking Code	Inspection Date	
RVS in 2006	7/17/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	0	0	0	0	-0.8	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Eagle Point High School

Final RVS Score

Final Type	Final Score
C2	2.8

FEMA-154 Collapse Potential

Low (<1%)



Eagle Point High School

Jack_sch19C

Enrollment 1218	Year Built (Field Verified) 1982	Year Built (Alt. Source) 1982	Est. Decade Built 1970
Total Area (square ft) 177000	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 NE General Site			

Eagle Point High School

Eagle Point SD 9

Jack_sch19D

Building Type	County	
School	Jackson	
Street		
203 N Platt Ave		
City	State	Zip
Eagle Point	OR	97524
Latitude	Longitude	
42.47519	122.80072	
Tracking Code	Inspection Date	
RVS in 2006	7/17/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Eagle Point High School

Final RVS Score

Final Type	Final Score
C2	0.3

FEMA-154 Collapse Potential

High (>10%)



Eagle Point High School

Jack_sch19D

Enrollment 1218	Year Built (Field Verified) 1982	Year Built (Alt. Source) 1982	Est. Decade Built 1970
Total Area (square ft) 177000	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E Plan Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries