

Rogue River Elementary School

Rogue River SD 35

Jack_sch20A

Building Type	County
School	Jackson
Street	
300 Pine St	
City	State Zip
Rogue River	OR 97537
Latitude	Longitude
42.43646	123.16982
Tracking Code	Inspection Date
RVS in 2006	7/19/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Rogue River Elementary School

Final RVS Score

Final Type	Final Score
RM1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rogue River Elementary School

Jack_sch20A

Enrollment 329	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 31784	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		None	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E Plan Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Rogue River Elementary School

Rogue River SD 35

Jack_sch20B

Building Type	County	
School	Jackson	
Street		
300 Pine St		
City	State	Zip
Rogue River	OR	97537
Latitude	Longitude	
42.43656	123.16916	
Tracking Code	Inspection Date	
RVS in 2006	7/19/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	0	0	-0.2	0	0	-0.6	0	1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Rogue River Elementary School

Final RVS Score

Final Type	Final Score
URM	1

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rogue River Elementary School

Jack_sch20B

Enrollment 329	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1930
Total Area (square ft) 31784	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions Cracks Poor Masonry Poor Concrete	
 NE Poor Condition		 N Poor Condition Also shows primary structure type.	
		 N Poor Condition There are some chunks of the building missing like this one.	

Rogue River Elementary School

Rogue River SD 35

Jack_sch20C

Building Type	County	
School	Jackson	
Street		
300 Pine St		
City	State	Zip
Rogue River	OR	97537
Latitude	Longitude	
42.43713	123.16918	
Tracking Code	Inspection Date	
RVS in 2006	7/19/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	0	-0.6	0	2.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Rogue River Elementary School

Final RVS Score

Final Type	Final Score
RM1	2.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rogue River Elementary School

Jack_sch20C

Enrollment 329	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 31784	Number of Stories 1	Basement No	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Rogue River Elementary School

Rogue River SD 35

Jack_sch20D

Building Type	County
School	Jackson
Street	
300 Pine St	
City	State Zip
Rogue River	OR 97537
Latitude	Longitude
42.43712	123.16959
Tracking Code	Inspection Date
RVS in 2006	7/19/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	0	-0.8	0	3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Rogue River Elementary School

Final RVS Score

Final Type	Final Score
W2	3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rogue River Elementary School

Jack_sch20D

Enrollment 329	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 31784	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards Unreinforced Chimneys None None		Poor Conditions None None None	
 S Falling Hazard			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries