

Jacksonville Elementary School

Medford SD 549C

Jack_sch27A

Building Type	County
School	Jackson
Street	
655 Hueners Ln	
City	State Zip
Jacksonville	OR 97530
Latitude	Longitude
42.3176	122.95824
Tracking Code	Inspection Date
RVS in 2006	7/19/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Jacksonville Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Jacksonville Elementary School

Jack_sch27A

Enrollment 401	Year Built (Field Verified) 1959	Year Built (Alt. Source) 1959	Est. Decade Built 1980
Total Area (square ft) 31832	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
Non-Parallel System		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E	Vertical Irregularity Primary	E	Vertical Irregularity Primary
			
		W Plan Irregularity Primary With Building "C"	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Jacksonville Elementary School

Jack_sch27B

Medford SD 549C

Building Type	County
School	Jackson
Street	
655 Hueners Ln	
City	State Zip
Jacksonville	OR 97530
Latitude	Longitude
42.31779	122.95768
Tracking Code	Inspection Date
RVS in 2006	7/19/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	0	0	0	-0.8	0	0	0.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Jacksonville Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.8

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Jacksonville Elementary School

Jack_sch27B

Enrollment 401	Year Built (Field Verified) 1959	Year Built (Alt. Source) 1959	Est. Decade Built 1980
Total Area (square ft) 31832	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
 E Vertical Irregularity Primary			

Jacksonville Elementary School

Medford SD 549C

Jack_sch27C

Building Type	County
School	Jackson
Street	
655 Hueners Ln	
City	State Zip
Jacksonville	OR 97530
Latitude	Longitude
42.31774	122.95868
Tracking Code	Inspection Date
RVS in 2006	7/19/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	-0.5	0	0	-0.8	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Jacksonville Elementary School

Final RVS Score

Final Type	Final Score
RM1	2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Jacksonville Elementary School

Jack_sch27C

Enrollment 401	Year Built (Field Verified) 1959	Year Built (Alt. Source) 1959	Est. Decade Built 1990
Total Area (square ft) 31832	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other Reentrant Corners: Other None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
N Plan Irregularity Primary			

Jacksonville Elementary School

Medford SD 549C

Jack_sch27D

Building Type	County
School	Jackson
Street	
655 Hueners Ln	
City	State Zip
Jacksonville	OR 97530
Latitude	Longitude
42.3171	122.95845
Tracking Code	Inspection Date
RVS in 2006	7/19/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Jacksonville Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Jacksonville Elementary School

Jack_sch27D

Enrollment 401	Year Built (Field Verified) 1959	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 31832	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Out of Plane Lateral-Force-Resistance Elements		Steps in Elevation View: Single Change	
Non-Parallel System		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S Plan Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries