

# Washington Elementary School

Medford SD 549C

Jack\_sch33A

Building Type	County	
School	Jackson	
Street		
610 S Peach St		
City	State	Zip
Medford	OR	97501
Latitude	Longitude	
42.31691	122.88313	
Tracking Code	Inspection Date	
RVS in 2006	7/21/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C1	3	0	-0.5	-1	0	0	-1	0	0.5
Secondary	C2	3.6	0	-0.5	-0.4	0	0	-1.2	0	1.5
Tertiary		0	0	0	0	0	0	0	0	0

Washington Elementary School

### Final RVS Score

Final Type	Final Score
C1	0.5

### FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Washington Elementary School

Jack\_sch33A

Enrollment 443	Year Built (Field Verified) 1920	Year Built (Alt. Source) 1920	Est. Decade Built 1920
Total Area (square ft) 40873	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
Out of Plane Lateral-Force-Resistance Elements		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
Reentrant Corners: Other		None	
Falling Hazards		Poor Conditions	
Other: Heavy cornice or other overhead decoration		None	
None		None	
None		None	
			
SE Elevation View		E Falling Hazard	
			
SW Vertical Irregularity Secondary		SW Vertical Irregularity Primary	
		<p>W Plan Irregularity Primary and plan irregularity: reentrant corner due to adjacent building.</p>	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Washington Elementary School

Medford SD 549C

Jack\_sch33B

Building Type	County
School	Jackson
Street	
610 S Peach St	
City	State Zip
Medford	OR 97501
Latitude	Longitude
42.31706	122.88371
Tracking Code	Inspection Date
RVS in 2006	7/21/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	-0.5	0	0	0	-0.6	0	4.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Washington Elementary School

## Final RVS Score

Final Type	Final Score
W1	4.1

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Washington Elementary School

Jack\_sch33B

Enrollment 443	Year Built (Field Verified) 1920	Year Built (Alt. Source) 1920	Est. Decade Built 1970
Total Area (square ft) 40873	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) Reentrant Corners: Other None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
 NW Plan Irregularity Primary			

# Washington Elementary School

Medford SD 549C

Jack\_sch33C

Building Type	County
School	Jackson
Street	
610 S Peach St	
City	State Zip
Medford	OR 97501
Latitude	Longitude
42.31722	122.88357
Tracking Code	Inspection Date
RVS in 2006	7/21/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	0	0	1.6	0	-0.6	0	6.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Washington Elementary School

## Final RVS Score

Final Type	Final Score
W1	6.2

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# Washington Elementary School

Jack\_sch33C

Enrollment 443	Year Built (Field Verified) 1920	Year Built (Alt. Source) 1920	Est. Decade Built 1980
Total Area (square ft) 40873	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
 NE Vertical Irregularity Primary			