

# Talent Elementary School

Phoenix-Talent SD 4

Jack\_sch47A

Building Type	County	
School	Jackson	
Street		
307 W Wagner St		
City	State	Zip
Talent	OR	97540
Latitude	Longitude	
42.24097	122.79195	
Tracking Code	Inspection Date	
RVS in 2006	6/29/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	-0.5	0	0	0	-1	0	2.3
Secondary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Tertiary		0	0	0	0	0	0	0	0	0

## Talent Elementary School

### Final RVS Score

Final Type	Final Score
RM1	1.9

### FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# Talent Elementary School

Jack\_sch47A

Enrollment 472	Year Built (Field Verified) 1989	Year Built (Alt. Source) 1989	Est. Decade Built 1980
Total Area (square ft) 50262	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities None None None	
Falling Hazards Other: General None None		Poor Conditions None None None	
			
W Elevation View		W Primary Structural Type	
		W Primary Structural Type	
			
W Field Verified Year Built		S Plan Irregularity Primary	
		W Other View of the inside.	
E Falling Hazard Covered walkway towards the front door and all over this school.			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Talent Elementary School

Phoenix-Talent SD 4

Jack\_sch47B

Building Type	County	
School	Jackson	
Street		
307 W Wagner St		
City	State	Zip
Talent	OR	97540
Latitude	Longitude	
42.24056	122.79157	
Tracking Code	Inspection Date	
RVS in 2006	6/29/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	0	0	0	-0.8	0	0	0.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

## Talent Elementary School

### Final RVS Score

Final Type	Final Score
RM1	0.8

### FEMA-154 Collapse Potential

High (>10%)



OregonGeology

# Talent Elementary School

Jack\_sch47B

Enrollment 472	Year Built (Field Verified) 1989	Year Built (Alt. Source) 1989	Est. Decade Built 1970
Total Area (square ft) 50262	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None None	
Falling Hazards Other: General None None		Poor Conditions None None None	
			
E Vertical Irregularity Primary		W Primary Structural Type Flexible diaphragm.	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Talent Elementary School

Phoenix-Talent SD 4

Jack\_sch47C

Building Type	County	
School	Jackson	
Street		
307 W Wagner St		
City	State	Zip
Talent	OR	97540
Latitude	Longitude	
42.24084	122.79099	
Tracking Code	Inspection Date	
RVS in 2006	6/29/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Talent Elementary School

## Final RVS Score

Final Type	Final Score
RM1	1.9

## FEMA-154 Collapse Potential

Moderate (>1%)



# Talent Elementary School

Jack\_sch47C

Enrollment 472	Year Built (Field Verified) 1989	Year Built (Alt. Source) 1989	Est. Decade Built 1970
Total Area (square ft) 50262	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards Other: General None None		Poor Conditions None None None	
 S Vertical Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Talent Elementary School

Phoenix-Talent SD 4

Jack\_sch47D

Building Type	County	
School	Jackson	
Street		
307 W Wagner St		
City	State	Zip
Talent	OR	97540
Latitude	Longitude	
42.24085	122.79137	
Tracking Code	Inspection Date	
RVS in 2006	6/29/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	0	0	0	0	-1.2	0	2.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Talent Elementary School

## Final RVS Score

Final Type	Final Score
RM1	2.4

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Talent Elementary School

Jack\_sch47D

Enrollment 472	Year Built (Field Verified) 1989	Year Built (Alt. Source) 1989	Est. Decade Built 1980
Total Area (square ft) 50262	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards Other: General		Poor Conditions None None None	

# Talent Elementary School

Phoenix-Talent SD 4

Jack\_sch47E

Building Type	County	
School	Jackson	
Street		
307 W Wagner St		
City	State	Zip
Talent	OR	97540
Latitude	Longitude	
42.24112	122.79103	
Tracking Code	Inspection Date	
RVS in 2006	6/29/2006	



Seismicity Zone: Moderate

**FEMA 154 Rapid Visual Screening Score Card**

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	0	0	0	0	-1.2	0	2.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

**Talent Elementary School**

**Final RVS Score**

Final Type	Final Score
RM1	2.4

**FEMA-154 Collapse Potential**

Low (<1%)
-----------



# Talent Elementary School

Jack\_sch47E

Enrollment 472	Year Built (Field Verified) 1989	Year Built (Alt. Source) 1989	Est. Decade Built 1970
Total Area (square ft) 50262	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
Other: General		None	
None		None	
None		None	



N Elevation View



N Vertical Irregularity Primary  
Also shows out of plane lateral system.



N Plan Irregularity Secondary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Talent Elementary School

Phoenix-Talent SD 4

Jack\_sch47F

Building Type	County	
School	Jackson	
Street		
307 W Wagner St		
City	State	Zip
Talent	OR	97540
Latitude	Longitude	
42.24104	122.79061	
Tracking Code	Inspection Date	
RVS in 2006	6/29/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	-0.5	0	2.4	0	-0.8	0	4.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Talent Elementary School

## Final RVS Score

Final Type	Final Score
W2	4.9

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Talent Elementary School

Jack\_sch47F

Enrollment 472	Year Built (Field Verified) 1989	Year Built (Alt. Source) 1989	Est. Decade Built 1990
Total Area (square ft) 50262	Number of Stories 1	Basement	Pounding Potential No
<b>Plan Irregularities</b> Reentrant Corners: Other Out of Plane Lateral-Force-Resistance Elements None		<b>Vertical Irregularities</b> Steps in Elevation View: 2 to 3 Changes None None	
<b>Falling Hazards</b> None None None		<b>Poor Conditions</b> None None None	
			
S Plan Irregularity Primary		E Plan Irregularity Primary	
		E Vertical Irregularity Primary also shows out of plane lateral system	
		W Vertical Irregularity Primary also show out of plane lateral system	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries