

# Prospect School

Prospect SD 59

Jack\_sch49A

Building Type	County	
School	Jackson	
Street		
160 Mill Creek Rd		
City	State	Zip
Prospect	OR	97536
Latitude	Longitude	
42.75342	122.48941	
Tracking Code	Inspection Date	
RVS in 2006	7/18/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	1.6	-0.8	0	0	5.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Prospect School

## Final RVS Score

Final Type	Final Score
W2	5.1

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# Prospect School

Jack\_sch49A

Enrollment 187	Year Built (Field Verified) 1980	Year Built (Alt. Source) 1980	Est. Decade Built 1980
Total Area (square ft) 33513	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	

# Prospect School

Prospect SD 59

Jack\_sch49B

Building Type	County
School	Jackson
Street	
160 Mill Creek Rd	
City	State Zip
Prospect	OR 97536
Latitude	Longitude
42.75352	122.48999
Tracking Code	Inspection Date
RVS in 2006	7/18/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	0	0	1.6	-0.8	0	0	5.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Prospect School

## Final RVS Score

Final Type	Final Score
W2	5.6

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Prospect School

Jack\_sch49B

Enrollment 187	Year Built (Field Verified) 1980	Year Built (Alt. Source) 1980	Est. Decade Built 1980
Total Area (square ft) 33513	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 SW General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Prospect School

Jack\_sch49C

Prospect SD 59

Building Type	County
School	Jackson
Street	
160 Mill Creek Rd	
City	State Zip
Prospect	OR 97536
Latitude	Longitude
42.75377	122.48935
Tracking Code	Inspection Date
RVS in 2006	7/18/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	1.6	-0.8	0	0	2.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Prospect School

## Final RVS Score

Final Type	Final Score
W2	2.1

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# Prospect School

Jack\_sch49C

Enrollment 187	Year Built (Field Verified) 1980	Year Built (Alt. Source) 1980	Est. Decade Built 1980
Total Area (square ft) 33513	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
 S Vertical Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Prospect School

Prospect SD 59

Jack\_sch49D

Building Type	County	
School	Jackson	
Street		
160 Mill Creek Rd		
City	State	Zip
Prospect	OR	97536
Latitude	Longitude	
42.75163	122.49059	
Tracking Code	Inspection Date	
RVS in 2006	7/18/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Prospect School

## Final RVS Score

Final Type	Final Score
W2	0.5

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

# Prospect School

Jack\_sch49D

Enrollment 187	Year Built (Field Verified) 1980	Year Built (Alt. Source) 1980	Est. Decade Built 1970
Total Area (square ft) 33513	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NW Plan Irregularity Primary		SW Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries