

# Evans Valley Elementary School

Rogue River SD 35

Jack\_sch50A

Building Type	County	
School	Jackson	
Street		
8205 E Evans Creek Rd		
City	State	Zip
Rogue River	OR	97537
Latitude	Longitude	
42.53884	123.1632	
Tracking Code	Inspection Date	
RVS in 2006	7/19/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	-1	0	0	0	0	0.3
Secondary	RM1	2.8	-1	-0.5	-1	0	0	0	0	0.3
Tertiary		0	0	0	0	0	0	0	0	0

Evans Valley Elementary School

## Final RVS Score

Final Type	Final Score
C2	0.3

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Evans Valley Elementary School

Jack\_sch50A

Enrollment 154	Year Built (Field Verified) 1924	Year Built (Alt. Source) 1920	Est. Decade Built 1920
Total Area (square ft) 23811	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W General Site	SE Plan Irregularity Primary	E Secondary Structural Type	
			
NE Primary Structural Type	E Vertical Irregularity Primary		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Evans Valley Elementary School

Rogue River SD 35

Jack\_sch50B

Building Type	County	
School	Jackson	
Street		
8205 E Evans Creek Rd		
City	State	Zip
Rogue River	OR	97537
Latitude	Longitude	
42.53937	123.16343	
Tracking Code	Inspection Date	
RVS in 2006	7/19/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	0	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Evans Valley Elementary School

## Final RVS Score

Final Type	Final Score
RM1	2.8

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# Evans Valley Elementary School

Jack\_sch50B

Enrollment 154	Year Built (Field Verified) 1924	Year Built (Alt. Source) 1924	Est. Decade Built 1950
Total Area (square ft) 23811	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 N General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries