

Elk Trail Elementary School

Jack_sch51A

Eagle Point SD 9

Building Type		County	
School		Jackson	
Street			
591 Elk Creek Rd			
City	State	Zip	
Trail	OR	97541	
Latitude		Longitude	
42.66771		122.74662	
Tracking Code		Inspection Date	
RVS in 2006		7/18/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	-0.2	0	-0.8	0	0	3.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Elk Trail Elementary School

Final RVS Score

Final Type

Final Score

W2

3.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
136		1936	1930
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
24090	1	Yes	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



E Plan Irregularity Primary



W Plan Irregularity Primary



Elk Trail Elementary School

Eagle Point SD 9

Jack_sch51B

Building Type		County	
School		Jackson	
Street			
591 Elk Creek Rd			
City	State	Zip	
Trail	OR	97541	
Latitude		Longitude	
42.6677		122.74698	
Tracking Code		Inspection Date	
RVS in 2006		7/18/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	-0.5	0	0	-0.6	0	0	2.7
Secondary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Tertiary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3

Elk Trail Elementary School

Final RVS Score

Final Type

Final Score

RM1

0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
136		1936	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
24090	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
Out of Plane Lateral-Force-Resistance Elements	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SW Plan Irregularity Primary

