

# Applegate Elementary School

Three Rivers/Josephine County SD

Jack\_sch53A

Building Type	County	
School	Jackson	
Street		
14188 Highway 238		
City	State	Zip
Jacksonville	OR	97530
Latitude	Longitude	
42.25397	123.15251	
Tracking Code	Inspection Date	
RVS in 2006	7/19/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	0	-0.5	-0.2	0	-0.4	0	0	0.7
Secondary	W1	4.4	0	-0.5	0	0	0	0	0	3.9
Tertiary		0	0	0	0	0	0	0	0	0

Applegate Elementary School

## Final RVS Score

Final Type	Final Score
URM	0.7

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Applegate Elementary School

Jack\_sch53A

Enrollment 137	Year Built (Field Verified) 1912	Year Built (Alt. Source) 1912	Est. Decade Built 1910
Total Area (square ft) 23759	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions Poor Masonry Cracks None	
 <p>W Poor Condition</p>			



**OregonGeology**

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Applegate Elementary School

Three Rivers/Josephine County SD

Jack\_sch53B

Building Type	County
School	Jackson
Street	
14188 Highway 238	
City	State Zip
Jacksonville	OR 97530
Latitude	Longitude
42.25432	123.15267
Tracking Code	Inspection Date
RVS in 2006	7/19/2006



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary		0	0	0	0	0	0	0	0	0

Applegate Elementary School

### Final RVS Score

Final Type	Final Score
W2	0.9

### FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Applegate Elementary School

Jack\_sch53B

Enrollment 137	Year Built (Field Verified) 1912	Year Built (Alt. Source) 1912	Est. Decade Built 1950
Total Area (square ft) 23759	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Very Irregular Changes	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
 SE General Site		 E Plan Irregularity Primary	

# Applegate Elementary School

Three Rivers/Josephine County SD

Jack\_sch53C

Building Type	County
School	Jackson
Street	
14188 Highway 238	
City	State Zip
Jacksonville	OR 97530
Latitude	Longitude
42.25456	123.15249
Tracking Code	Inspection Date
RVS in 2006	7/19/2006



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	0	0	0	-0.4	0	0	2.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Applegate Elementary School

## Final RVS Score

Final Type	Final Score
RM1	2.4

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Applegate Elementary School

Jack\_sch53C

Enrollment 137	Year Built (Field Verified) 1981	Year Built (Alt. Source) 1912	Est. Decade Built 1980
Total Area (square ft) 23759	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
E Field Verified Year Built			